

**TESTING FOR THE VERIFICATION OF COMPLIANCE  
OF PV INVERTER WITH :**

**ANEXO III DEL PROCEDIMIENTO DE VERIFICACIÓN,  
VALIDACIÓN Y CERTIFICACIÓN DE LOS REQUISITOS  
DEL P.O. 12.3 FRENTE A LA RESPUESTA DE LAS  
INSTALACIONES EÓLICAS Y SOLARES ANTE  
HUECOS DE TENSIÓN (PVVC VERSIÓN 10).**

Procedure: PE.T-LE-61

Test Report Number .....: 2214 / 0337 / Amp2 / E1 (\*)

This report modifies and replaces report Nº 2214 / 0337 / Amp2 (\*)

(\*) See Test Report Historical Revision table on page 2.

Type .....: 3Play

Tested Model .....: INGECON SUN 33TL M

Variants Models .....: INGECON SUN 28TL M; INGECON SUN 28TL;  
INGECON SUN 33TL; INGECON SUN 24TL M480  
INGECON SUN 40TL M480

**APPLICANT**

Name .....: INGETEAM POWER TECHNOLOGY

Address .....: Av. Ciudad de la Innovación, 13  
31621 Sarriguren, Navarra (Spain)

**TESTING LABORATORY**

Name .....: SGS Tecnos, S.A.U (Electrical Testing Laboratory)

Address .....: C/ Trespaderne, 29 - Edificio Barajas 1  
28042 MADRID (Spain)

Conducted (tested) by .....: Omar Kalim  
(Project Engineer)

Reviewed & Approved by .....: Fernando Montes  
(Laboratory Manager)

Date of issue .....: 21/12/2015

Number of pages .....: 35



## Anexo III del PVVC versión 10

**Important Note:**

- This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at [www.sgs.com/terms\\_and\\_conditions.htm](http://www.sgs.com/terms_and_conditions.htm) and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at [www.sgs.com/terms\\_e-document.htm](http://www.sgs.com/terms_e-document.htm). Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents.
- This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

**Test Report Historical Revision:**

Test Report Version	Date	Resume
2214 / 0337 / Amp2	10-11-2015	--
2214 / 0337 / Amp2 – E1	21-12-2015	<p>Editorial changes.</p> <p>Models added in this version:            INGECON SUN 24TL M480; INGECON SUN 40TL M480</p> <p>See pages 1 and 6.</p>

**Anexo III del PVVC versión 10**

**INDEX**

<b>1</b>	<b>SCOPE .....</b>	<b>4</b>
<b>2</b>	<b>GENERAL INFORMATION .....</b>	<b>5</b>
2.1	Testing Period and Climatic conditions .....	5
2.2	Equipment under Testing.....	5
2.3	SGS Test Equipment List .....	7
2.4	Measurement Uncertainty.....	7
2.5	Definitions.....	8
2.6	Test set up.....	8
<b>3</b>	<b>RESUME OF TEST RESULTS .....</b>	<b>9</b>
<b>4</b>	<b>TEST RESULTS.....</b>	<b>10</b>
4.1	LVRT test.....	10
4.1.1	Symmetrical faults. ....	11
4.1.2	Asymmetrical faults.....	21
<b>5</b>	<b>PICTURES .....</b>	<b>30</b>
<b>6</b>	<b>ELECTRICAL SCHEMES .....</b>	<b>35</b>

**Anexo III del PVVC versión 10****1 SCOPE**

SGS Electrical Testing Laboratory has been contract by INGETEAM POWER TECHNOLOGY in order to perform the testing according the Anexo III del procedimiento de verificación, validación y certificación de los requisitos del P.O. 12.3 frente a la respuesta de las instalaciones eólicas y solares ante huecos de tensión (PVVC versión 10).

## Anexo III del PVVC versión 10

**2 GENERAL INFORMATION****2.1 TESTING PERIOD AND CLIMATIC CONDITIONS**

The necessary testing has been performed along one working day on 22<sup>th</sup> of September 2015.

All the tests and checks have been performed in accordance with the reference Standard.

Temperature: Initial 22,5 °C; Final 22,1 °C

Pressure: Initial 41,8%HR; Final 41,3% HR

**SITES TEST**

Name ..... : INGETEAM POWER TECHNOLOGY  
 Address ..... : Av. Ciudad de la innovación, 13  
 Sarriguren, Navarra (Spain)

**2.2 EQUIPMENT UNDER TESTING**

Apparatus type/ Installation ..... : Three Phase Solar Inverter / Fixed installation  
 Manufacturer/ Supplier/ Installer ..... : INGETEAM  
 Trade mark ..... : INGETEAM  
 Model ..... : INGECON SUN 33 TL M  
 Serial Number ..... : 360000150830  
 Software Version ..... : ABI 1000  
 Rated Characteristics ..... : Input: 200-820 V<sub>dc</sub> (1000Vmax); I<sub>scPV</sub>= 40 A  
 Output: 3x380 V / 3x400 V<sub>ac</sub>; I<sub>acMAX</sub>=48A; 3 ~NPE;  
 f=50 / 60 Hz; 33kW

Date of manufacturing: 2014

## Test item particulars

Input ..... DC  
 Output ..... 3 ~NPE  
 Class of protection against electric shock ..... Class I  
 Degree of protection against moisture ..... IP 65  
 Type of connection to the main supply ..... Three phase – Fixed installation  
 Cooling group ..... Heat Sink  
 Modular ..... No  
 Internal Transformer ..... No

## Anexo III del PVVC versión 10

## Rating Plate:



Type: 3 Play

Model fully tested: INGECON SUN 33TL M

The variant model is: INGECON SUN 28TL M; INGECON SUN 28TL; INGECON SUN33 TL; INGECON SUN 24TL M480; INGECON SUN 40TL M480.

The variant model has been included in this test report without tests because the following features don't change regarding to the tested model:

- Same connection system and hardware topology
- Same control algorithm.
- Same Firmware Version
- Output power between  $\pm 2,5$  of the power tested.
- Output rated current  $\pm 50\%$  of the model tested.

The results obtained apply only to the particular sample tested and the variants model that is the subject of the present test report. The most unfavorable result values of the verifications and tests performed are contained herein.

Throughout this report a comma is used as the decimal separator.

**Anexo III del PVVC versión 10**
**2.3 SGS TEST EQUIPMENT LIST**

EQUIPMENT	MARK/MODEL	SGS CODE (DIE)	CALIBRATION DATE
Oscilloscope	Yokogawa / DL850	630040	19/02/2015 to 19/02/2016
Power analyzer	Yokogawa / WT3000	510014	11/06/2015 to 11/06/2016
4 Voltage Probe	Sapphire / SI-9010	610300-06	7/11/2014 to 7/11/2015
		610300-07	15/10/2014 to 15/10/2015
		610300-10	
		610300-11	
Multimeter	Fluke/289	560020	26/08/2015 to 26/08/2016
3 Current clamp	HIOKI / 9669	510010-2 510010-4 510010-6	28/05/2015 to 28/05/2016
Digital Thermohyrometer	Testo / 622	840051	19/02/2015 to 19/02/2016

The test bench used includes:

EQUIPMENT	MARK/MODEL	RATED CHARACTERISTICS
AC Source	AMETEK / MX60-3PI-400-LAN-MB-SNK	Input 72 kVA 400 V 50-60Hz Output 60 kVA 150 / 300 V 16-819 Hz
DC Source	CHROMA / 62150H-1000S	15 kW Output: 200 V / 1000 V 6 A / 15 A

**2.4 MEASUREMENT UNCERTAINTY**

Voltage measurement uncertainty	±1,5 %
Current measurement uncertainty	±2,0 %
Frequency measurement uncertainty	±0,2 %
Time measurement uncertainty	±0,2 %
Power measurement uncertainty	±2,5 %
Phase Angle	±1°
cosφ	±0,01


Note: The measurement uncertainties associated with other parameters measured during the tests are in the laboratory at disposal of the solicitant.

## 2.5 DEFINITIONS

Ea	Active Energy	P	Active Power
Er	Reactive Energy	p.u	Per unit
In	Nominal Current	Pn	Nominal Power
Ir	Reactive Current	Q	Reactive Power
Itot	Total Current	Sn	Apparent Power
LVRT	Low Voltage Righth Through		

## 2.6 TEST SET UP.

Below is the simplified construction of the test set up.



Different equipment has been used to take measures as it shows in chapter 2.3. Current and voltage clamps have been connected to the inverter output for all the tests.

All the tests described in the following pages have used this specified test setup.



**Anexo III del PVVC versión 10**
**3 RESUME OF TEST RESULTS**
**INTERPRETATION KEYS**


Test object does meet the requirement .....	<b>P</b>	Pass
Test object does not meet the requirement .....	<b>F</b>	Fails
Test case does not apply to the test object .....	<b>N/A</b>	Not applicable
To make a reference to a table or an annex.....		See additional sheet
To indicate that the test has not been realized.....	<b>N/R</b>	Not realized

<b>POWER VERIFICATION</b>	
<b>It has been verified that the solar inverter supplies different power levels.</b>	
P > 80% P <sub>n</sub>	P
10 % P <sub>n</sub> < P < 30% P <sub>n</sub>	P
<b>VERIFICATION OF DIPS WITH NO LOAD</b>	
<b>It has been verified that the dip generator is capable to supply the different levels of voltage drop during the required time.</b>	
Symmetrical fault: T > 500 ms & U <sub>res</sub> < 20% U <sub>n</sub>	P
Asymmetrical fault: T > 500ms & U <sub>res</sub> < 60% U <sub>n</sub>	P
<b>TESTS AND VERIFICATIONS</b>	
<b>Insensitivity to voltage dips</b>	
The equipment remains connected during the test	P
Visual Inspection of the EBE before and after the perturbation	P

## 4 TEST RESULTS

### 4.1 LVRT TEST

The LVRT test has been done according with the next figure:



Where:

$U_{res1}$ = Minimum voltage value measured	$T_1$ = LVRT start instant
$U_{ref1}$ = Minimum voltage value measured plus 3%	$T_2$ = Instant when U is lower than $U_{ref1}$
$U_{res2}$ = Voltage value measured	$T_3$ = Instant when U is lower than $U_{ref2}$
$U_{ref2}$ = Voltage value measured plus 3%	$T_4$ = LVRT finish instant

$U_{res2}$  is defined in order to considerate a variation in the voltage level inside the LVRT however the LVRT performed only have one voltage minimum level because of this in this case voltage levels  $U_{res1}$  and  $U_{res2}$  are the same levels. Same argument is applied to  $U_{ref1}$  and  $U_{ref2}$ .

- A zone: All the voltage values between  $T_2$  and  $T_2 + 150$  ms
- B zone: All the voltages values between  $T_2 + 150$  ms and  $T_3$ .
- C zone: All the voltage values between and  $T_4$  or  $T_3 + 150$  ms whichever is lower

**Anexo III del PVVC versión 10**
**4.1.1 Symmetrical faults.**

The test has been performed at two power levels. Each power level is repeated three times ensuring a voltage level lower than 20% of  $U_n$  and a fault duration higher than 500 ms.

- Requirements for A zone:  
Q consumption has to be lower than 60% of  $P_n$  measured during 20 ms.
- Requirements for B zone:  
P consumption has to be lower than 10% of  $P_n$  measured during 20 ms.  
 $I_r/I_{tot}$  media has to be higher than 90%.
- Requirements for C zone:  
 $E_r$  consumption has to be lower than 60% of  $P_n$  measured during 150 ms.  
 $I_r$  has to be lower than 1,5 per unit measured during 20 ms.

First Test at $P > 80\% P_n$					
Power Desired / Measured		Voltage Level Desired / Measured		Time Desired / Measured	
> 80% $P_n$	81,99 %	< 20% $U_n$	15,09 %	> 500	568,7 ms
P.O. 12.3 Requirements				Results	
ZONE A					
Q < 60 % $P_n$ (20 ms)		-0,6 p.u.		0,116 p.u	
ZONE B					
P < 10 % $P_n$ (20 ms)		-0,1 p.u.		0,002 p.u	
$I_r/I_{tot}$ average		0,9 p.u.		0,999 p.u	
ZONE C					
$E_r$ < 60 % $P_n$ * 150 ms		-90 ms.pu		14,185 ms p.u	
$I_r$ < 1,5 $I_n$ (20 ms)		-1,5 p.u.		0,848 p.u	




**Anexo III del PVVC versión 10**

Second Test at P > 80% Pn					
Power Desired / Measured		Voltage Level Desired / Measured		Time Desired / Measured	
> 80% Pn	81,93 %	< 20% Un	15,11 %	> 500	568,8 ms
P.O. 12.3 Requirements				Results	
ZONE A					
Q < 60 % Pn (20 ms)		-0,6 p.u.		0,117 p.u	
ZONE B					
P < 10 % Pn (20 ms)		-0,1 p.u.		0,002 p.u	
Ir/ltot average		0,9 p.u.		0,999 p.u	
ZONE C					
Er < 60 % Pn * 150 ms		-90 ms.pu		14,192 ms p.u	
Ir < 1,5 In (20 ms)		-1,5 p.u.		0,847 p.u	

Third Test at P > 80% Pn					
Power Desired / Measured		Voltage Level Desired / Measured		Time Desired / Measured	
> 80% Pn	81,95 %	< 20% Un	15,06 %	> 500	568,9 ms
P.O. 12.3 Requirements				Results	
ZONE A					
Q < 60 % Pn (20 ms)		-0,6 p.u.		0,116 p.u	
ZONE B					
P < 10 % Pn (20 ms)		-0,1 p.u.		0,002 p.u	
Ir/ltot average		0,9 p.u.		0,999 p.u	
ZONE C					
Er < 60 % Pn * 150 ms		-90 ms.pu		14,17 ms p.u	
Ir < 1,5 In (20 ms)		-1,5 p.u.		0,846 p.u	




Anexo III del PVVC versión 10

First Test at P > 80% Pn




Anexo III del PVVC versión 10

Second Test at P > 80% Pn



Anexo III del PVVC versión 10

Third Test at P > 80% Pn



**Anexo III del PVVC versión 10**

First Test at 10% < P < 30% Pn					
Power Desired / Measured		Voltage Level Desired / Measured		Time Desired / Measured	
20% Pn	19,58 %	< 20% Un	15,01 %	> 500	559,6
P.O. 12.3 Requirements				Results	
ZONE A					
Q < 60 % Pn (20 ms)		-0,6 p.u.		0,022 p.u	
ZONE B					
P < 10 % Pn (20 ms)		-0,1 p.u.		0,0004 p.u	
Ir/Itot average		0,9 p.u.		0,999 p.u	
ZONE C					
Er < 60 % Pn * 150 ms		-90 ms.pu		4,057 ms p.u	
Ir < 1,5 In (20 ms)		-1,5 p.u.		0,234 p.u	

Second Test at 10% < P < 30% Pn					
Power Desired / Measured		Voltage Level Desired / Measured		Time Desired / Measured	
20% Pn	19,58 %	< 20% Un	15,02 %	> 500	568,9
P.O. 12.3 Requirements				Results	
ZONE A					
Q < 60 % Pn (20 ms)		-0,6 p.u.		0,021 p.u	
ZONE B					
P < 10 % Pn (20 ms)		-0,1 p.u.		0,002 p.u	
Ir/Itot average		0,9 p.u.		0,999 p.u	
ZONE C					
Er < 60 % Pn * 150 ms		-90 ms.pu		4,062 ms p.u	
Ir < 1,5 In (20 ms)		-1,5 p.u.		0,234 p.u	






**Anexo III del PVVC versión 10**

Third Test at 10% < P < 30% Pn					
Power Desired / Measured		Voltage Level Desired / Measured		Time Desired / Measured	
20% Pn	19,56 %	< 20% Un	15,04 %	> 500	568,9
P.O. 12.3 Requirements				Results	
ZONE A					
Q < 60 % Pn (20 ms)		-0,6 p.u.		0,022 p.u	
ZONE B					
P < 10 % Pn (20 ms)		-0,1 p.u.		0,0002 p.u	
Ir/ltot average		0,9 p.u.		0,999 p.u	
ZONE C					
Er < 60 % Pn * 150 ms		-90 ms.pu		2,413 ms p.u	
Ir < 1,5 In (20 ms)		-1,5 p.u.		0,216 p.u	



Anexo III del PVVC versión 10

First Test at 10% < P < 30% Pn






Anexo III del PVVC versión 10

Second Test at 10% < P < 30% Pn



Anexo III del PVVC versión 10

Third Test at 10% < P < 30% Pn



**Anexo III del PVVC versión 10**
**4.1.2 Asymmetrical faults**

The test has been performed at two power levels. Each power level is repeated three times ensuring a voltage level lower than 20% of  $U_n$  and a fault duration higher than 500 ms.

- Requirements for A zone:

No requirements.

- Requirements for B zone:

$E_r$  consumption has to be lower than 40% of  $P_n$  measured during 100 ms.

$Q$  consumption has to be lower than 40% of  $P_n$  measured during 20 ms.

$E_a$  consumption has to be lower than 45% of  $P_n$  measured during 100 ms.

$P$  consumption has to be lower than 10% of  $P_n$  measured during 20 ms.

- Requirements for C zone:

No requirements.

First Test at $P > 80\% P_n$					
Power Desired / Measured		Voltage Level Desired / Measured		Time Desired / Measured	
> 80% $P_n$	81,93 %	< 60% $U_n$	55,24%	> 500	559,1ms
P.O. 12.3 Requirements				Results	
ZONE B					
$E_r < 40\% P_n * 100$ ms		-40 ms.pu		59,818 ms.pu	
$Q < 40\% P_n$ (20 ms)		-0,4 p.u.		0,598 p.u	
$E_a < 45\% P_n * 100$ ms		-45 ms.pu		0,541 ms.pu	
$P < 30\% P_n$ (20 ms)		-0,3 p.u.		0,006 ms p.u	




Second Test at $P > 80\% P_n$					
Power Desired / Measured		Voltage Level Desired / Measured		Time Desired / Measured	
> 80% $P_n$	81,97 %	< 60% $U_n$	55,27%	> 500	559,2ms
P.O. 12.3 Requirements				Results	
ZONE B					
$E_r < 40\% P_n * 100$ ms		-40 ms.pu		59,897 ms.pu	
$Q < 40\% P_n$ (20 ms)		-0,4 p.u.		0,598 p.u	
$E_a < 45\% P_n * 100$ ms		-45 ms.pu		0,596 ms.pu	
$P < 30\% P_n$ (20 ms)		-0,3 p.u.		0,006 ms p.u	

**Anexo III del PVVC versión 10**

Third Test at P > 80% Pn					
Power Desired / Measured		Voltage Level Desired / Measured		Time Desired / Measured	
> 80% Pn	81,88 %	< 60% Un	55,11%	> 500	559,4 ms
P.O. 12.3 Requirements				Results	
ZONE B					
Er < 40 % Pn * 100 ms		-40 ms.pu		59,767 ms.pu	
Q < 40 % Pn (20 ms)		-0,4 p.u.		0,597 p.u	
Ea < 45 % Pn * 100 ms		-45 ms.pu		0,590 ms.pu	
P < 30 % Pn (20 ms)		-0,3 p.u.		0,006 ms p.u	




Anexo III del PVVC versión 10

First Test at P > 80% Pn



Anexo III del PVVC versión 10




Second Test at P > 80% Pn





Anexo III del PVVC versión 10

Third Test at P > 80% Pn



**Anexo III del PVVC versión 10**




First Test at 10% < P < 30% Pn					
Power Desired / Measured		Voltage Level Desired / Measured		Time Desired / Measured	
20% Pn	19,64 %	< 60% Un	55,16%	> 500	559,4ms
P.O. 12.3 Requirements				Results	
ZONE B					
Er < 40 % Pn * 100 ms		-40 ms.pu		15,983 ms.pu	
Q < 40 % Pn (20 ms)		-0,4 p.u.		0,160 p.u	
Ea < 45 % Pn * 100 ms		-45 ms.pu		-0,256 ms.pu	
P < 30 % Pn (20 ms)		-0,3 p.u.		-0,002 ms p.u	

Second Test at 10% < P < 30% Pn					
Power Desired / Measured		Voltage Level Desired / Measured		Time Desired / Measured	
20% Pn	19,57 %	< 60% Un	55,01%	> 500	559,6ms
P.O. 12.3 Requirements				Results	
ZONE B					
Er < 40 % Pn * 100 ms		-40 ms.pu		15,996 ms.pu	
Q < 40 % Pn (20 ms)		-0,4 p.u.		0,160 p.u	
Ea < 45 % Pn * 100 ms		-45 ms.pu		-0,249 ms.pu	
P < 30 % Pn (20 ms)		-0,3 p.u.		-0,002 ms p.u	

Third Test at 10% < P < 30% Pn					
Power Desired / Measured		Voltage Level Desired / Measured		Time Desired / Measured	
20% Pn	19,56 %	< 60% Un	55,00%	> 500	559,7ms
P.O. 12.3 Requirements				Results	
ZONE B					
Er < 40 % Pn * 100 ms		-40 ms.pu		15,999 ms.pu	
Q < 40 % Pn (20 ms)		-0,4 p.u.		0,160 p.u	
Ea < 45 % Pn * 100 ms		-45 ms.pu		-0,259 ms.pu	
P < 30 % Pn (20 ms)		-0,3 p.u.		-0,002 ms p.u	




Anexo III del PVVC versión 10

First Test at 10% < P < 30% Pn






Anexo III del PVVC versión 10

Second Test at 10% < P < 30% Pn



Anexo III del PVVC versión 10

Third Test at 10% < P < 30% Pn



## Anexo III del PVVC versión 10

## 5 PICTURES

