

Product certificate number

No: 2614/0337/D1-CER/E1

Manufacturer

INGETEAM POWER TECHNOLOGY
Pol. Industrial El Juncarillo Nave 1, 31293 Sesma, Navarra, Spain

Trademark

Ingeteam

Type

1Play

Model

INGECON SUN 2.5TL M / INGECON SUN 2.7TL M / INGECON SUN 3TL M /
INGECON SUN 3.3TL M / INGECON SUN 3.68TL M / INGECON SUN 4.6TL M /
INGECON SUN 5TL M / INGECON SUN 5.5TL M / INGECON SUN 6TL M

Type of generating unit

Static Power Converter

Technical Data

| | | | |
|-----------------------|--------------------------|-----------------------------|------------------------|
| Nominal Power | 2,5 kW 3,3 kW 5 kW | 2,7 kW 3,68 kW 5,5 kW | 3 kW 4,6 kW 6 kW |
| Nominal Voltage | 220 / 230 / 240 V | | |
| Nominal Frequency | 50 Hz | | |
| Firmware version | ABE1000 | | |
| Number of phases | Single phase | | |
| Isolation Transformer | NO | | |

Standard

EN 50438:2013. Requirements for micro-generating plants to be connected in parallel with public low-voltage distribution networks

This certificate is based upon the test results of the Test Report nº 2614/0337-D1.

The above-mentioned generating unit is certified according the SGS internal process 4 based on the requirements of the UNE-EN ISO / IEC 17065.

This certificate supersedes the certificate 2614/0337/D1-CER

This certificate is valid until: 09th of April 2021

Madrid, 09th of April 2018



Daniel Arranz Muñiz
Certification Manager

