



Product certificate number

Manufacturer

Туре

Model

Type of generating unit

Technical Data

No: 2614/0325/Amp4/1-CER/E1

Static Power Converter			
Nominal Power	2,5 kW 3,3 kW 5 kW	2,7 kW 3,68 kW 5,5 kW	3 kW 4,6 kW 6 kW
Nominal Voltage	220 V / 230 V / 240 V		
Nominal Frequency	50 Hz		
Firmware version	ABE1000		
Number of phases	Single phase		
Isolation Transformer			

INGECON SUN 2.5TL M / INGECON SUN 2.7TL M / INGECON SUN 3TL M / INGECON SUN 3.3TL M / INGECON SUN 3.68TL M / INGECON SUN 4.6TL M / INGECON SUN 5TL M / INGECON SUN 5.5TL M / INGECON SUN 6TL M

Pol. Industrial El Juncarillo Nave 1, 31293 Sesma, Navarra, Spain

Standard

G59 Issue 3:2013, Recommendation for the connection of generating plant to the distribution systems of licensed distribution network operators.

The above-mentioned generating unit is certified according the SGS internal procedure PE.T-ECPE-20 based on the requirements of the UNE-EN ISO/IEC 17065.

INGETEAM POWER TECHNOLOGY

1Play

This certificate supersedes the certificate number 2614/0325/Amp4/1-CER.

This certificate is valid until: 13th of January of 2021.

Madrid, 13th of January 2018

Daniel Arranz Muñiz Certification Manager



SGS Tecnos, S.A.U. c/ Trespaderne, 29 - 28042 Madrid Tif: 91 313 80 00; Fax: 91 313 80 93 www.sgs.es This certificate is issued by SGS under its General Conditions for Product Certification at www.sgs.com/terms_and_conditions This document cannot be reproduced partially

SG