



Product certificate number

No: 2614/0325/B1/E2-CER/E1

Manufacturer	INGETEAM POWER TECHNOLOGY Pol. Industrial El Juncarillo Nave 1, 31293 Sesma, Navarra, Spain			
Trademark	Ingeteam			
Туре	1Play			
Model	INGECON SUN 2.5TL M / INGECON SUN 2.7TL M / INGECON SUN 3TL M / INGECON SUN 3.3TL M / INGECON SUN 3.68TL M / INGECON SUN 4.6TL M / INGECON SUN 5TL M / INGECON SUN 5.5TL M / INGECON SUN 6TL M			
Type of generating unit	Static Power Converter			
Technical Data	Nominal Power	2,5 kW 3,3 kW 5 kW	2,7 kW 3,68 kW 5,5 kW	3 kW 4,6 kW 6 kW
	Rated Voltage Nominal Frequency		220/230/240 V 50 Hz	
	Firmware version		ABE1000	
	Number of phases		Single phase	
	Isolation Transformer		NO	
Standard	IEC 62116:2014, Utility-intercor prevention measures	nected photovoltaic inve	rters – Test procedure o	f islanding

The above-mentioned generating unit is certified according the SGS internal procedure PE.T-ECPE-18 based on the requirements of the UNE-EN ISO/IEC 17065.

This certificate supersedes certificate number 2614/0325/B1/E2-CER.

This certificate is valid until: 21th of June 2020

Madrid, 21th of June 2017

Daniel Arranz Muñiz Certification Manager



SGS Tecnos, S.A.U. c/ Trespaderne, 29 - 28042 Madrid Tlf: 91 313 80 00; Fax: 91 313 80 93 www.sgs.es This certificate is issued by SGS under its General Conditions for Product Certification at www.sgs.com/terms_and_conditions. This document cannot be reproduced partially

SGS

N° 2614/0325/B1/E2-CER/E1 Page 1 of 1