

Product certificate number

No: 2614/0337/J11-CER/E1

Manufacturer

INGETEAM POWER TECHNOLOGY
Pol. Industrial El Juncarillo Nave 1, 31293 Sesma, Navarra, Spain

Trademark

Ingeteam

Type

1Play

Model

INGECON SUN 2.5TL M / INGECON SUN 2.7TL M / INGECON SUN 3TL M /
INGECON SUN 3.3TL M / INGECON SUN 3.68TL M / INGECON SUN 4.6TL M /
INGECON SUN 5TL M / INGECON SUN 5.5TL M / INGECON SUN 6TL M

Type of generating unit

Static Power Converter

Technical Data

Nominal Power	2,5 kW	2,7 kW	3 kW
	3,3 kW	3,68 kW	4,6 kW
	5 kW	5,5 kW	6 kW
Nominal Voltage	220 / 230 / 240 V		
Nominal Frequency	60 Hz		
Firmware version	ABE1000		
Number of phases	Single phase		
Isolation Transformer	NO		

Standard

IEEE Std 929-2000: IEEE Recommended Practice for Utility Interface of Photovoltaic (PV) Systems.

This certificate is based upon the test results of the Test Report n° 2614/0337-J11.

The above-mentioned generating unit is certified according the SGS internal process 4 based on the requirements of the UNE-EN ISO / IEC 17065.

This certificate supersedes the certificate number 2614/0337/J11-CER

This certificate is valid until: 09th of April 2021

Madrid, 09th of April 2018

Daniel Arranz Muñoz
Certification Manager

