



Product Certificate Number	11505-32-CER Ingeteam Power Technology S.A Energy Avenida Ciudad De La Innovación, 13. 31621. Sarriguren. Navarra. SPAIN			
Applicant				
Model/	INGECON SUN 100TL			
Series/	INGECON SUN 3Play TL Series			
Type of generating unit	Photovoltaic Inverter			
Technical Data	See page 2			
Network connection rule	IEC 61000-3-12: 2011. EMC - Part 3-12: Limits - Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current > 16 A and <= 75 A per phase. - Chapter 5 IEC 61000-3-4: 1998. EMC Part 3-4: Limits - Limitation of emission of harmonic currents in low-voltage power supply systems for equipment with rated current greater than 16 A. - Chapter 5			

Having assessed the test report number: 11505-1-TR performed by Certification Entity for Renewable Energies, S.L. (EA Acredited Laboratory Nº 1239/LE2396) based on the requirements of the EN ISO/IEC 17025:2005.

The above-mentioned generating unit complies with the requirements of the:

IEC 61000-3-12: 2011. EMC - Part 3-12: Limits - Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current > 16 A and <= 75 A per phase. (Chapter 5)

IEC 61000-3-4: 1998. EMC -- Part 3-4: Limits - Limitation of emission of harmonic currents in low-voltage power supply systems for equipment with rated current greater than 16 A. (Chapter 5)

This certification is according the CERE internal process PET-CERE-09 Rev 10 based on the requirements of the EN ISO/IEC 17065:2012. For this certification process the conformity assessment activities were based on:

- Testing of production samples selected by CERE.
- Audit of quality system according ISO 9001 with certificate number: 0. 04. 12231 issued by a certification body accredited according EN ISO/IEC 17021.
- Inspection of the manufacturing process.

Madrid at July 17, 2017. This certificate is valid until July 17, 2020

Miguel Martínez Lavin Certification Manager






INGETEAM INGECON SUN 100TL

DC INPUT							
Recommended PV-Power	92.7 - 160 kWp	97.9 - 160 kWp	103-160 kWp	108.2 - 160 kWp	113.3 - 160 kWp		
Voltage range MPP	513 - 850 V	541.5 - 850 V	570 - 850 V	598.5 - 850 V	627 - 850 V		
Maximum Voltage	1100 V						
Max. DC Current	185 A						
Max. DC short-circuit Current	240 A						
Inputs (STD / PRO)	1/24						
MPPT	1						
AC OUTPUT							
Rated Power @ rated Vac	90 kW	95 kW	100 kW	105 kW	110 kW		
Max. temperature @ rated P	50°C						
Max. Current	145 A						
Rated Voltage	360 V	380 V	400 V	420 V	440 V		
Frequency	50 Hz						
Power Factor	1						
Power Factor adjustable	Yes. Smax=90 kVA Qmax=54 kVAR	Yes. Smax=95 kVA Qmax=57 kVAR	Yes. Smax=100 kVA Qmax=60 kVAR	Yes. Smax=105 kVA Qmax=63 kVAR	Yes. Smax=110 kVA Qmax=66 kVAR		
THD	<3%						





Electrical Diagram of INGETEAM INGECON SUN 100TL



Manufacturer: Ingeteam Power Technology S.A.

Pol. Ind. El Juncanillo nave 1 E-31293. Sesma. Navarra. SPAIN

The sample selected to test was representative of the production. April 24, 2017 The sample was selected in manufacture facilities.

Sample Report Number: 11505-1-TM

The inspection of manufacturing process was performed in June 27, 2017 manufacture facilities:

Inspection Report Number: 11505-IF