



N° 147/C-PR335				
Product Certificate Number	11505-6-CER			
Applicant	Ingeteam Power Technology S.A Energy Avenida Ciudad De La Innovación, 13. 31621. Sarriguren. Navarra. SPAIN			
Model/	INGECON SUN 100TL			
Type of generating unit	Photovoltaic Inverter			
Technical Data	See page 2			
Network connection rule	IEC 62116: 2014 (At 50 & 60 Hz). Utility-interconnected photovoltaic Inverters-Test procedure of islanding prevention measures.			

Having assessed the test report number: 11505-6-TR performed by Certification Entity for Renewable Energies, S.L. (EA Acredited Laboratory Nº 1239/LE2396) based on the requirements of the EN ISO/IEC 17025:2005.

The above-mentioned generating unit complies with the requirements of the: **IEC 62116: 2014** (At 50 & 60 Hz). Utility-interconnected photovoltaic Inverters-Test procedure of islanding prevention measures.

This certification is according the CERE internal process PET-CERE-09 Rev 11 based on the requirements of the EN ISO/IEC 17065:2012. For this certification process the conformity assessment activities were based on:

- Testing of production samples selected by CERE.
- Audit of quality system according ISO 9001 with certificate number: 0. 04. 12231 issued by a certification body accredited according EN ISO/IEC 17021.
- Inspection of the manufacturing process.

Madrid at September 27, 2017. This certificate is valid until September 27, 2020


Miguel Martínez Lavin Certification Manager

Phone: + 34 91 146 01 10

INGETEAM INGECON SUN 100TL

DC INPUT							
Recommended PV-Power	92.7 - 160 kWp	97.9 - 160 kWp	103-160 kWp	108.2 - 160 kWp	113.3 - 160 kWp		
Voltage range MPP	513 - 850 V	541.5 - 850 V	570 - 850 V	598.5 - 850 V	627 - 850 V		
Maximum Voltage	1100 V						
Max. DC Current	185 A						
Max. DC short-circuit Current	240 A						
Inputs (STD / PRO)	1/24						
MPPT	1						
AC OUTPUT							
Rated Power @ rated Vac	90 kW	95 kW	100 kW	105 kW	110 kW		
Max. temperature @ rated P	50°C						
Max. Current	145 A						
Rated Voltage	360 V	380 V	400 V	420 V	440 V		
Frequency	50 / 60 Hz						
Power Factor	1						
Power Factor adjustable	Yes. Smax=90 kVA Qmax=54 kVAR	Yes. Smax=95 kVA Qmax=57 kVAR	Yes. Smax=100 kVA Qmax=60 kVAR	Yes. Smax=105 kVA Qmax=63 kVAR	Yes. Smax=110 kVA Qmax=66 kVAR		
THD	<3%						

Electrical Diagram of INGETEAM INGECON SUN 100TL



The sample selected to test was representative of the production. The sample was selected in:

Ingeteam Power Technology S.A. Pol. Ind. El Juncanillo nave 1 E-31293. Sesma. Navarra. SPAIN

11505-1-TM

Sample Report Number:

The inspection of manufacturing process was performed in: On 27^{th} of June of 2017

Ingeteam Power Technology S.A. Pol. Ind. El Juncanillo nave 1 E-31293. Sesma. Navarra. SPAIN

Inspection Report Number: 11505-IF