

# Certificate of Conformity

By the product certificate number:

No. 2620/0119-D1-CER

Issued to

License holder: **INGETEA POWER TECHNOLOGY**  
Av. Ciudad de la Innovación, 13  
31621 Sarriguren, Navarra (España)

Factory: **INGETEA POWER TECHNOLOGY**  
Pol. Industrial El Juncarillo Nave1  
31293 Sesma, Navarra, Spain

Trademark: **Ingeteam**



It is certified that the product:

Type of generator: Single phase grid connected inverter for Photovoltaic and Energy Storage System

Family: 1Play

Models: INGECON SUN STORAGE 1Play 3TL M <sup>(1)</sup> / INGECON SUN STORAGE 1Play 3TL M Basic <sup>(1)</sup>  
INGECON SUN STORAGE 1Play 6TL M <sup>(2)</sup> / INGECON SUN STORAGE 1Play 6TL M Basic <sup>(2)</sup>

Technical Data:	Rated Active Power	3 kW <sup>(1)</sup>	6 kW <sup>(2)</sup>
	Rated Voltage	220 - 240 V	
	Rated Frequency	50 Hz	
	Firmware version	ABH1007 (for 1Play TL M models) ABH1006 (for 1Play TL M Basic models)	
	Number of phases	Single Phase	
	Isolation transformer	NO	

Is in compliance with the standard:

- **Engineering Recommendation G98. Issue 1, Amendment 4. June 2019.**  
Requirements for the connection of Fully Type Tested Micro-generators (up to and including 16 A per phase) in parallel with public Low Voltage Distribution Networks on or after 27 April 2019.

This certificate is based upon the test results of the Test Report nº 2220-0119-D. The testing process has been carried out according the SGS internal procedure PE.T-LE-62 based on the requirements of the UNE-EN ISO / IEC 17025.

The above-mentioned generating unit is certified according to the SGS internal process no. 4 based on the requirements of the UNE-EN ISO/IEC 17065.

This certificate is first issued on: 11<sup>th</sup> May 2021.

This certificate is valid until: 11<sup>th</sup> May 2024.

Madrid, 11<sup>th</sup> May 2021



Daniel Arranz Muñiz  
Certification Manager

