

**ABI - Familia de inversores fotovoltaicos trifásicos TL para
conexión directa a redes de distribución / Family of TL three-
phase photovoltaic inverters for direct connection to distribution
networks**

FW DISPLAY INGECON SUN 3PLAY TLM

ABI1002IPB02_D.DOCX

**IPB - DESCRIPCIÓN DE REVISIONES DE SOFTWARE /
SOFTWARE REVISION DESCRIPTION**

Haga clic aquí para escribir texto.

Realizado por / <i>Elaborated by:</i>	G.A.E.
Fecha creación / <i>Created:</i>	05/05/2015
Revisado por / <i>Revised by:</i>	A.C.O.
Aprobado por / <i>Approved by:</i>	M.B.A.
Fecha de aprobado / <i>Approval date:</i>	04/11/2016
Documento / <i>Document:</i>	ABI1002IPB02_D.docx
Plantilla / <i>Template:</i>	IPB_D.dotx

Tabla de contenido / Table of contents

1	VER._C. Released on 2015/05/05.....	3
1.1	New feature.....	3
1.2	Changed from previous version	3
1.3	Bug fixed.....	3
2	VER._D. Released on 2015/09/16.....	4
2.1	New feature.....	4
2.2	Changed from previous version	4
2.3	Bug fixed.....	4
3	VER._E. Released on 2016/02/23.....	5
3.1	New feature.....	5
3.2	Changed from previous version	7
3.3	Bug fixed.....	7
4	VER._F. Released on 2016/05/12	8
4.1	New feature.....	8
4.2	Changed from previous version	8
4.3	Bug fixed.....	8
5	VER._G. Released on 2016/11/04	9
5.1	New feature.....	9
5.2	Changed from previous version	9
5.3	Bug fixed.....	9

1 VER._C. Released on 2015/05/05

1.1 New feature

Display now starts with screen off to avoid blinking at starting on mornings or ending at night

Graphics are scalable now in X axis in power graph and in Y axis in Energy graph

New screen to modify cosPhi and the sign.

Lock screen option added to protect inverter against any modification.

New self consumption screen added

New Vac added for Mexican regulation Vac= 254 V.

New Vac split phase added: Vac= 240 V Split phase

1.2 Changed from previous version

VF settings names are changed for Italian regulations.

Changed names for some Spanish regulations.

1.3 Bug fixed

An error in day energy graph is fixed. The error affects to the end hour calculation.

Error in daily production is fixed. The graphic was not correct when the production passes 8 hours.

2 VER._D. Released on 2015/09/16

2.1 New feature

United Arab Emirates country is added with DEWA regulation

Digital input and backup mode are created but aren't available yet.

2.2 Changed from previous version

Self consumption changed. In ESPAÑA country there is no possibility to change Power set point neither to revert self consumption if selected.

2.3 Bug fixed

Exit from FW update screen wasn't refreshed always so sometimes couldn't exit from processing.

Solved problem using SD card. Sometimes a reset could happen if previously a reset command was sent.

3 VER._E. Released on 2016/02/23

3.1 New feature


Added NETBILLING regulation for Chile country.

Added new V/F parameter configuration in advanced settings.

Added Waiting time configuration in Advanced settings

The V/F Settings and the Connection Waiting Time Settings are shown in the "Inverter Data" menu.

Here we can see the correspondence between the monitored data on the screen and those indicated in CHILE NETBILLING standard.



2016-2-03	16:05	Ajustes V/F T.VacH2 T.VacH1 T.VacL1 T.VacL2	100ms 100ms 100ms 100ms	Tiempo Protección contra sobretensiones breves V>> Tiempo Protección contra caídas de tensión V<
2016-2-03	16:05	Ajustes V/F T.FacH2 T.FacH1 T.FacL1 T.FacL2	100ms 100ms 100ms 100ms	Tiempo. Protección contra subidas de la frecuencia F> Tiempo. Protección contra caída de la frecuencia F<
2016-2-03	16:05	Ajustes V/F Modo VacAvg	Habilitado 242V	Protección contra sobretensiones (media 10-minutos) V>
2016-2-03	16:05	Ajustes V/F Modo VacHOFF VacLOFF	Habilitado 242V 187V	Límite Superior de tensión V> Límite inferior de tensión V<
2016-2-03	16:05	Ajustes V/F Modo FacHOFF FacLOFF	Habilitado 50.20 Hz 47.50 Hz	Límite Superior de frecuencia F> Límite Inferior frecuencia F<
2016-2-03	16:05	Tiempo de Espera Estándar Especial Modo Esp.	60 s 60 s Deshabilitado	Tiempo reconexión. Incluido desconexiones breves.

3.2 Changed from previous version

Settings menu and advanced settings menu haven't anymore Not available options.

3.3 Bug fixed

Solved problem changing some variables they weren't updated after modification.

Solved problem when display sends FW version data to inverter. Now there is a specific function to do that.

4 VER._F. Released on 2016/05/12

4.1 New feature

Added new 3 PLAY 33 KW and 40 KW features.

Added new screens for string configuration.

4.2 Changed from previous version

Some Vac values in country regulation are not available for a 33 KW or 40 KW inverters.

4.3 Bug fixed

5 VER._G. Released on 2016/11/04

5.1 New feature

Added new screen for auxiliary digital input configuration to allow on/off purpose. Auxiliary digital input can be configured to start and to stop the inverter. This input can be used, for example, to fulfill with Australian regulation, working as DRM0 command.

New countries added: New Zealand, El Salvador and Egypt have been added to “country regulation” display menu.

New regulations added:

- BDEW has been added in WORLDWIDE menu.
- FRANCE HV has been added in WORLDWIDE menu.
- PANAMA GRID CODE has been added in WORLDWIDE menu.
- N20 has been added in WORLDWIDE menu.
- AS4777 NEW ZEALAND has been added.
- EL SALVADOR has been added.
- EGYPTERA has been added.

5.2 Changed from previous version

AS4777 has been updated to 2015 revision.

5.3 Bug fixed