

CASE STUDY

KIVA PUMP STATION Rehab
ALBUQUERQUE, NM



INDAR SP UGP

Task: Up-Grade the pump station from ~ 4,500 GPM (1,022 m³/h) to ~ 12,000 GPM (2,725 m³/h). Required electrical service, hydraulic surge arrestor, pump control valves, suction and discharge headers.



Indar
Ingeteam Group

INDAR SPUGP Pump: UGP-M-2125-02

Hm: 170 ft **Q:** 5000 USgpm

Motor: ML-37-4/100-W

P: 225 / 300 (kW/HP) **V:** 480 V

n: 1750 (rpm) **I:** 351 (A) **f:** 60 (Hz)

N: 106909, 107009, 107109 **max.submergence** 200

2009

www.indar.net
water@ingeteam.com Tel.: 00 34 943 02 82 00



Indar
Ingeteam Group


Before the conversion



Because of the limited space (height and length) it was not possible to provide the new flow requirement of 12,000 GPM (2,725 m³/h) with traditional vertical turbine pumps. INDAR inverted submersible pumps and motors were selected to fulfill the requirement.



New Hydraulic Surge Tank




After the conversion



This picture shows the three, 300 HP (225kW) submersible pumps in line.

Pump station's new suction header and suction cans



INDAR Low Suction Submersible Pumping Units.



The picture shows the intake system.